



Mine Safety Appliances Company • P.O. Box 427 • Pittsburgh, PA 15230

Gasgard/Quad Gas II Monitors - ATO Order Form

Gasgard 8

A-Gasgard 8



1



2



3

1

Number of Channels

- 1 = One Channel Card & One Relay Module
- 2 = Two Channel Cards & Two Relay Modules
- 3 = Three Channel Cards & Three Relay Modules
- 4 = Four Channel Cards & Four Relay Modules
- 5 = Five Channel Cards & Five Relay Modules
- 6 = Six Channel Cards & Six Relay Modules
- 7 = Seven Channel Cards & Seven Relay Modules
- 8 = Eight Channel Cards & Eight Relay Modules

2

Output

- 0 = 4-20mA Standard
- 1 = RS-232
- 2 = RS-485

3

Options

- 0 = None
- C = Custom

Accessories

- 10029955 Gasgard 8 channel upgrade card w/display
- 10029956 Gasgard 8 channel upgrade relay

Gasgard 1

- 10029991 Single channel, wall mount, 115 Vac, Nema 12, 4 levels of alarm and fault relays, 4-20mA output/input
- 10029992 Single channel, wall mount, 230 Vac, Nema 12, 4 levels of alarm and fault relays, 4-20mA output/input

QuadGas II

- 215345 Control Monitor Nema 4X, 110 VAC
- or
- 216322 Control Monitor Nema 4X, 220 VAC
- Includes:
- Discrete Warning Relays
- Common Alarm Relay
- Common Trouble Relay
- 215346 Control Monitor Nema 4X, 110 VAC
- or
- 216323 Control Monitor Nema 4X, 220 VAC
- Includes:
- Discrete Warning Relays
- Discrete Alarm Relay
- Common Trouble Relay

Note: Use 2 or 3 wire 4-20mA sensors.